

Solar PV Feasibility Study Albany Unified School District

May 2023



101 Lucas Valley Road, Suite 302, San Rafael, CA 94903
(415) 663-9914 | www.sagerenew.com

Table of Contents

| | |
|---|-----------|
| 1. Executive Summary | 3 |
| 1.1 Overview | 3 |
| 1.2 Quantitative Results..... | 3 |
| 1.3 Key Points and Findings..... | 5 |
| 1.4 Recommendations and Next Steps | 5 |
| 2. Methods | 7 |
| 2.1 Scope and Goals | 7 |
| 2.2 Data Collection | 7 |
| 2.3 Conceptual Designs & Sizing..... | 7 |
| 2.4 Financial Modeling..... | 8 |
| 3. Results | 12 |
| 3.1 Consumption and Target PV Production | 12 |
| 3.2 System Siting, Sizing and Performance | 13 |
| 3.3 Tariff Modeling Results | 13 |
| 3.4 Lifecycle Modeling | 14 |
| 3.5 Site-by-Site Analysis..... | 15 |
| 3.6 Sensitivity and Risk Analysis..... | 16 |
| 4. Key Points and Considerations..... | 17 |
| 4.1 Key Points and Findings..... | 17 |
| 4.2 Schedule..... | 18 |
| Attachment A. 25-Year Financial Model Summary..... | 21 |
| Attachment B. Annual Production Reports | 22 |
| Attachment C. Sensitivity and Risk Analysis..... | 23 |
| Attachment D. Acronym Glossary | 26 |

1. Executive Summary

1.1 Overview

This study reviews the feasibility of installing solar photovoltaic (PV) systems at six public school facilities operated by the Albany Unified School District (District). The objective of this study is to conceptualize the siting and sizing of PV systems and estimate financial performance of solar PV financed through a Power Purchase Agreement (PPA). The study includes a site assessment, evaluation of historical and future electrical consumption, conceptual designs of potential PV systems, and a financial analysis of the proposed solar PV project. Per the District's expressed preference, the conceptual layout of the PV systems includes a combination of elevated shade and carport canopies and rooftop array, depending on the site.

Based on the findings of this study, a solar PV project is viable at the six targeted District sites. The solar PV project will save the District money over the life of the project, assuming recent market prices, and will provide positive and substantial 25-year nominal and net present value (NPV) project savings.

1.2 Quantitative Results

Based on the site assessment, utility tariff analysis, and financial modeling, Table 1 and Table 2 summarize the key metrics of this feasibility study. Attachment A provides the 25-year financial modeling analysis summary for each financing option.

Table 1. Summary of Project Evaluated

| | |
|-----------------------------------|---|
| Targeted Sites | 6 Sites (12 Services) |
| Total Designed System Size | 1,258 kilowatt peak (kWp) |
| Energy Consumption Offset Target | 80-85%, by site |
| Energy Consumption Offset Average | 86% |
| Energy Cost Offset Average | 64% |
| Financing | PPA |
| Environmental Benefit, 25-year | 3,700 Tons of Carbon Dioxide (CO ₂) |
| Shade Created by Project | 38,000 Square Feet (ft ²) |

Table 2. 25-Year Project Financial Summary, all six Targeted Sites

| | Units | No PV (Utility Only) | PV, PPA Financed (\$0.28/kWh) |
|--|-----------------------------|-------------------------|-------------------------------------|
| Energy Cost | \$, Nominal | \$26,253,000 | \$24,075,000 |
| District Soft Costs (Consultant, Inspections, Legal/Admin, Bond Issuance) | \$, Nominal | N/A | \$180,000 |
| Simple Payback | Years | N/A | 11.8 |
| 25-Year Savings | \$, Nominal | \$0 | \$1,997,000 |
| 25-Year Savings | \$, NPV, 2.0% DR | \$0 | \$1,325,000 |

1.3 Key Points and Findings

1. The project will result in substantial savings to the District over the lifetime of the project.
2. The PV market is dynamic, particularly at present. Risks to these returns include recent federal tax reform, International Trade Commission module import tariffs, and utility tariff changes. These risks were accounted for in this analysis, with further detail below. Even with negative results from these risks considered in modeling, the District should see substantial savings with solar implementation at the targeted sites.
3. Specifically, a risk to PV projects is the future of Net Energy Metering (NEM) in California. The Net Billing Tariff (NBT, otherwise known as NEM 3.0) went into effect on April 15, 2023 and substantially reduces the value of solar generation. The District has greatly mitigated this risk by submitting Interconnection Applications (IA) to PG&E which were Deemed Complete prior to the April deadline, to ensure the sites are grandfathered into the existing NEM 2.0 program. Substantial changes to the designs submitted in the IAs, however, could jeopardize the NEM 2.0 grandfathering of the projects and should therefore be handled with care.
4. The project will provide significant financial, environmental and shade benefit.
5. The early-stage evaluation of the desktop feasibility analysis ruled out the financial viability of BESS, so it was not included in the desktop feasibility or the investment grade feasibility study. However, as utility tariffs change over time demand charges are likely to become a greater fraction of the bill, so the District should consider reevaluating BESS financial feasibility every 5 years.

1.4 Recommendations and Next Steps

For the implementation of solar PV at the 6 District sites, NV5 would recommend the following steps for implementation:

1. District review of this study to assess if the financial, environmental and shade estimates meet District goals, expectations, and means. Go/no-go decision for procurement.
2. Generate a project milestone schedule in coordination with District review schedule, Board schedule, and District construction timeline.
3. Utilize an RFP to solicit competitive proposals from pre-qualified solar vendors for the project under California Government Code Section 4217.10 et seq. (allowing for a best value evaluation of proposals) including all acceptable financing options.
4. Evaluate proposals for qualitative and quantitative items and rank vendors with a committee of District stakeholders. Go/no-go decision to enter contract negotiations with a selected vendor.
5. Conduct contract negotiations with the highest ranked solar vendor with the assistance of District legal counsel and solar PV project consultant. Go/no-go decision to sign contract and move forward.

6. Enlist expertise during design, construction, and commissioning to represent the District and ensure adherence to the RFP requirements.

The above recommended process for this project will take approximately 18 to 24 months from the issuance of RFPs to Interconnect and Project Closeout. The implementation schedule in Table 14 shows the key milestones for implementing a PV system at the six sites.

2. Methods

The following process was used to develop this feasibility study.

2.1 Scope and Goals

NV5 met with and corresponded with the District to assess the scope, constraints, and goals of the potential project. Overall, the desire is to identify the most cost-effective opportunities at each site, within the constraints of existing and planned campus modernization plans.

2.2 Data Collection

Historical electricity consumption data from March 2022 to March 2023 were obtained from PG&E for all services at each site. The historical annual usage data were evaluated and planned changes to electrical energy consumption were considered to assess future usage. For planned lighting retrofits at Albany HS, Albany MS, Cornell ES, and Child Care Center, annual energy reductions from Willdan were used to estimate future energy consumption. At Marin ES, which is undergoing a substantial rebuild, annual energy consumption estimates were provided by LCA Architects. See Table 9 for specific consumption assumptions used in this analysis.

2.3 Conceptual Designs & Sizing

Preliminary layouts were designed as part of the Desktop Feasibility Review in March 2022 to identify potential PV array locations. These layouts were subsequently reviewed and modified with input from the District in April 2023. These reviews considered current proposed construction, future development plans, site restrictions (e.g., property lines, easements), and District preferences. System sizes were based on an 80-85% target usage offset to maximize the system size and minimize the annual energy portion of the bill. Model assumptions are detailed in Table 3.

Conceptual system designs were created and simulated solar PV production data were generated using industry-standard solar design software HelioScope. The conceptual designs were updated with multiple iterations as District and stakeholders provided input. The solar PV layout concepts provided as Attachment B are sufficient to utilize in an RFP to solicit design-build proposals.

Table 3. PV Siting and Sizing Assumptions

| Solar Production Modeling | |
|-------------------------------|---|
| Solar Insolation Data | Oakland Metropolitan Airport (TMY3) |
| Soiling Assumption | Moderate, seasonal soiling ~4% monthly loss assumed |
| PV Modules used in Helioscope | LG Electronics, LG 450 N2W-E6, 450 Watt |
| Inverters used in Helioscope | Canopy: SMA string inverters (33.3 kW, 50 kW, 62.5 kW) Rooftop: SolarEdge string inverters (33.3 kW, 40 kW) |
| Installation Type | Elevated canopy (typical Division of State Architect (DSA) Pre-Check structures) Rooftop: Unirac RM5 and Flush mount |
| PV System Lifetime | 25 years |

2.4 Financial Modeling

The solar PV financial models are greatly influenced by the input assumptions. NV5 uses conservative pricing assumptions based on market knowledge from other similar projects, current industry trends and utility escalation rates based on historical averages over the past forty years. If utility rates increase more over time in the future due to increased regulations, demand, and finite resources, the financial performance of the systems will be affected positively. Conversely, if rates increase slower than historical averages, the financial performance will be negatively affected. This variability is assessed in NV5's risk analysis, discussed in later sections.

Pricing Assumptions

Recent market data were used to arrive at the various financing prices. Values were adjusted based on recent DSA projects for sites similar to the District sites and any site-specific requirements. See Table 13 for assumed PPA rate by site.

Table 4. Solar PV Pricing Assumptions

| PV Pricing Information | |
|------------------------|---|
| PPA Price | <ul style="list-style-type: none"> - \$0.28 per kWh (blended average of site-by-site pricing) - Assumes soft costs will be paid by the District: 2.2% (Consultant Fees, Inspector of Record (IOR)/Testing, Legal/Admin, Interconnection Fees) |

Tariff Modeling

NV5 performed modeling for each site using the Energy Toolbase solar analytics program, NV5's proprietary modeling and PG&E's projected future applicable utility tariff rates to optimize system

sizing and cost offsets for each site. Modeling included projected electricity consumption and simulated PV production for conceptual designs.

The following are a few key concepts considered in design and tariff modeling that are integral to how PV projects generate value for behind-the-meter installations.

Net Energy Metering (NEM)

Under NEM, when a PV system produces more power than is used at the site at any instant, the excess energy is fed back into the utility system grid and the customer is credited for the cost of the excess electricity generated. This proposed solar project would be interconnected under the NEM 2.0 Guidelines, given the Deemed Complete status prior to the April 2023 deadline. NEM 2.0 is grandfathered for 20 years from the date of initial operation of the additional solar PV system, after which point, exported energy is likely to have a lower value. NV5 models a significant drop in the value of PV energy after year 20 due to upcoming NEM 3.0 Guidelines.

Net Energy Meeting Aggregation (NEMA)

Under NEMA, a single customer with multiple meters on the same property, or on the customer's adjacent or contiguous property, can use renewable energy generation and to serve their aggregated load behind all eligible meters. The site with PV (generating account) produces energy for itself and the adjacent meters (load or benefitting accounts). The exported energy is allocated based off the proportion of the most recent year's usage for all meters.

NEMA was assessed at all locations with multiple electric meters. In order to maximize the system sizes and sitewide energy offset, three sites were modeled with NEMA arrangements: two meters at Albany MS, three meters at Child Care Center, and five meters at Cornell ES.

Community Choice Aggregation (CCA)

Nearly all of the District's facilities purchase their energy from East Bay Community Energy (EBCE), the local CCA, while the energy is delivered and billed by PG&E. All the assessed meters have opted in to EBCE's Renewable 100 tariff option, which provides 100% solar and wind energy at a slight cost premium to the standard energy mix. The one exception is Albany HS, which receives bundled service from PG&E. This analysis assumes that the same arrangements will hold after the solar PV is installed at each site. See Table 5 for details.

PG&E Solar-Friendly Tariffs

Tariff modeling completed in this analysis assumes that all eligible sites maintain enrollment in PG&E's solar-friendly rates, including Option R and B-6. PG&E's Option R and B-6 tariffs are structured to provide greater value to NEM solar PV projects by trading higher energy rates for lower demand rates. Option R is available as a variant of B-19 and B-20 on a voluntary basis for all metered non-residential customers who otherwise qualify for those rates and have operational distributed generation with a capacity equal to or greater than 15% of their peak annual load. The District's larger meters (those currently on the B-10 tariff) were assessed for a voluntary opt-up to B-19 Option

R, though none of the meters showed a benefit from doing so. All of the smaller meters (those currently on the B-1 tariff) showed a benefit from switching to B-6 once the solar PV is installed.

Table 5 summarizes the tariff assumptions used in the tariff analysis model.

Table 5. Tariff Assumptions

| Site | Current Tariff | Modeled Tariff, with PV |
|--|---------------------------|---------------------------|
| Albany HS | PG&E B-10S | PG&E B-10S |
| Albany MS | EBCE B-10S, Renewable 100 | EBCE B-10S, Renewable 100 |
| Child Care Center (Generating Meter) | EBCE B-1, Renewable 100 | EBCE B-6, Renewable 100 |
| Child Care Center (Benefitting Meter #1) | EBCE B-1, Renewable 100 | EBCE B-6, Renewable 100 |
| Child Care Center (Benefitting Meter #2) | EBCE B-1, Renewable 100 | EBCE B-6, Renewable 100 |
| Cornell ES (Generating Meter) | EBCE B-1, Renewable 100 | EBCE B-6, Renewable 100 |
| Cornell ES (Benefitting Meter #1) | EBCE B-1, Renewable 100 | EBCE B-6, Renewable 100 |
| Cornell ES (Benefitting Meter #2) | EBCE B-1, Renewable 100 | EBCE B-6, Renewable 100 |
| Cornell ES (Benefitting Meter #3) | EBCE B-1, Renewable 100 | EBCE B-6, Renewable 100 |
| Cornell ES (Benefitting Meter #4) | EBCE B-1, Renewable 100 | EBCE B-6, Renewable 100 |
| Marin ES | EBCE B-10S, Renewable 100 | EBCE B-10S, Renewable 100 |
| Ocean View ES | EBCE B-10S, Renewable 100 | EBCE B-10S, Renewable 100 |

Lifecycle Financial Modeling

Financial analysis of the District-wide solar project was performed utilizing the results of the tariff modeling, including lifecycle cost analysis and analysis of the PPA financing option.

NV5 assumed the project will be grandfathered under NEM 2.0 regulations for 20 years, which govern the value of energy exported to the utility grid when PV production exceeds onsite consumption. Modeling assumptions considered risks associated with changes in utility TOU schedules, rates, and conditions.

Table 6 summarizes the key model inputs and assumptions used in the financial analysis model.

Table 6. Financial Modeling Assumptions

| Financial Information | |
|---------------------------------------|--|
| NEM 2.0 Export Energy Rate | Full retail rate, minus non-bypassable charges, for 20 years |
| Annual Utility Inflation Rate | 3.0% |
| Annual Utility Tariff Risk Factor | -0.10%, loss in value of PV energy due to utility rate structure changes |
| NEM 2.0 Loss (2044) | -25%, loss in value of PV energy after NEM 2.0 expires in 20 years |
| Net Present Value (NPV) Discount Rate | 2.0% |

Sensitivity Risk Analysis

NV5 assessed the impacts of key project variables on the economic outcomes of projects by conducting both a sensitivity analysis and a probability distribution risk analysis. The sensitivity analysis helps identify which variables have the most significant impact on the financial performance of the project and the probability distribution via a multivariable Monte Carlo analysis establishes a 90 percent probability envelope for financial performance over the lifetime of the project.

Assumptions and variables worth noting for PV projects in California are the significant risk of utility tariffs changing over time, which can lower the value of solar energy produced and impact financial returns from a project. NV5 has evaluated these potential risks and changes in assessing the tariff-based risks to project returns.

Table 7 summarizes the key project variables used for the Optimistic, Expected, and Conservative assumptions included in the sensitivity analysis. Based on the findings, the following were the top eight variables and assumptions that had the most financial impact on the project:

Table 7. PPA Sensitivity Analysis Assumptions

| Parameter | Optimistic | Expected | Conservative |
|---|------------|----------|--------------|
| Utility Annual Energy Escalator | 4.0% | 3.00% | 2.0% |
| PPA Price w/Soft Costs, PV Only, \$/kWh | \$0.252 | \$0.280 | \$0.309 |
| System Production Degradation per Year | 0.38% | 0.75% | 1.13% |
| Energy Value Change #2 (NEM 20-yr) | -22.5% | -25.0% | -27.5% |
| Tariff Rate Change Value Risk, per year | -0.08% | -0.10% | -0.13% |
| Installed System Cost | \$7.43 M | \$8.18 M | \$9.00 M |
| PPA Host Consultant Fees | 0.8% | 1.0% | 1.2% |
| PPA Host Testing and Inspection | 0.8% | 1.0% | 1.2% |

3. Results

3.1 Consumption and Target PV Production

Table 8 shows the estimated Year-1 utility consumption information for the six targeted sites. Table 9 shows the historical annual electrical usages for each of the 13 services. Attachment B shows the site details, proposed siting and layout of the solar arrays and interconnection points for each site.

Table 8. Annual Utility Consumption and Costs

| Year-1 Utility Consumption Information (for 6 targeted sites) | |
|---|---|
| Annual Design Electric Consumption | 2,166,000 kWh/Year for the 6 targeted sites |
| Annual Electric Cost | \$720,000 |
| Average Cost of Electricity | \$0.3324 per kWh |

Table 9. Historical Consumption

| Site No. | Site | SAID | Meter Number | March 2022-23 Gross Consumption (kWh) | Annual Energy Savings from Lighting Retrofit ¹ (kWh) | Annual Energy Design Consumption (kWh) |
|----------|-----------------------|------------|--------------|---------------------------------------|---|--|
| 1 | Albany HS | 5822709185 | 1010078634 | 1,182,700 | 170,300 | 1,012,400 |
| 2 | Albany MS | 7737511667 | 1010283867 | 472,600 | 121,200 | 351,400 |
| 3 | Child Care Center | 5637156202 | 1007303985 | 63,000 | 4,200 | 58,800 |
| | | 9572668063 | 1009330484 | 1,000 | 100 | 900 |
| | | 5637156269 | 1010473363 | 8,400 | 600 | 7,900 |
| 4 | Cornell ES | 5637156402 | 1009539569 | 143,800 | 30,900 | 112,900 |
| | | 0289088147 | 1007054618 | 21,800 | 4,700 | 17,100 |
| | | 9945928515 | 1009724351 | 11,700 | 2,500 | 9,200 |
| | | 5864388810 | 1005712694 | 10,500 | 2,300 | 8,300 |
| | | 5637156748 | 1005715454 | 14,700 | 3,200 | 11,500 |
| 5 | Marin ES ² | 5639321541 | 1010128022 | N/A | 0 | 205,600 |
| 6 | Ocean View ES | 5637156346 | 1009482408 | 363,300 | 0 | 363,300 |
| | Total | -- | -- | 2,294,000 | 340,000 | 2,159,000 |

¹ Willdan Energy Solutions quotes (10/27/2022); for sites with multiple meters, savings assumed to be proportional to current consumption per meter.

² Due to substantial rebuild at Marin ES, Design Consumption is based on estimates from the architect rather than historical consumption.

3.2 System Siting, Sizing and Performance

During the conceptual design phase, elevated carport and shade canopies and rooftop arrays were considered for the PV arrays based on District preferences. All of the target sites contain sufficient available space to meet the PV production targets with standard solar PV equipment. Table 10 provides a summary of the system siting, sizing, and performance findings.

Table 10. PV Siting, Sizing and Performance Findings

| Site No. | Site | Year-1 Target PV Production ¹ (kWh) | Year-1 Modeled PV Production (kWh) | Modeled System Size (kWp) | Year 1 Yield (kWh/kWp) | Shade Canopy Area (SF) |
|----------|-------------------|--|------------------------------------|---------------------------|------------------------|------------------------|
| 1 | Albany HS | 809,900 | 791,800 | 530.6 | 1,492 | 13,700 |
| 2 | Albany MS | 281,100 | 334,300 | 223.6 | 1,495 | 13,400 |
| 3 | Child Care Center | 54,100 | 64,400 | 44.2 | 1,457 | 2,600 |
| 4 | Cornell ES | 127,200 | 141,500 | 96.8 | 1,462 | 5,800 |
| 5 | Marin ES | 174,800 | 208,000 | 143.1 | 1,453 | 0 |
| 6 | Ocean View ES | 308,800 | 322,600 | 220.1 | 1,466 | 2,900 |
| | Total | 1,756,000 | 1,863,000 | 1,258 | 1,480 | 38,000 |

¹ Target production determined using target offset percentages established during Desktop Feasibility stage, applied to Design Consumption as shown in Table 9.

3.3 Tariff Modeling Results

The main electric meters at the six District sites were used for the tariff analysis and seven additional meters were assessed for NEMA at the Albany MS, Child Care Center, and Cornell ES sites. Table 11 shows the usage and bill offset and Year-1 savings with PV for each site. The target usage offset was approximately 80-85% for each site.

Table 11. Utility Tariff Analysis

| Site No. | Site | Usage Offset, PV (%) | Bill Offset, PV (%) | Year-1 Savings (\$) |
|----------|-------------------|----------------------|---------------------|---------------------|
| 1 | Albany HS | 78% | 62% | \$194,700 |
| 2 | Albany MS | 95% | 73% | \$83,600 |
| 3 | Child Care Center | 95% | 91% | \$22,300 |
| 4 | Cornell ES | 89% | 89% | \$50,500 |
| 5 | Marin ES | 101% | 64% | \$48,500 |
| 6 | Ocean View ES | 89% | 49% | \$64,000 |
| | Total | 87% | 65% | \$464,000 |

3.4 Lifecycle Modeling

Given the estimated PPA prices for the systems at the District, our analysis projects the District to pay more in total energy costs with PV than without for the first 5 years of the PPA term, assuming a 0% escalation on the PPA rate. As utility energy costs escalate, the sites will start to save money, resulting in projected lifetime savings for the project. This financial analysis shows that the District will pay 9% more in energy cost in the first year, with a steady increase in cumulative savings each year through the life of the project, peaking in year 20, when compared to purchasing electricity from the utility company. Cumulative energy costs and savings for cash financing are shown below in Table 12. The decrease in percent savings is due to degradation of the solar PV modules. Over time, the modules will produce about 0.75% less energy per year, on average. See Attachment A for full Cash Flows over the life of the system.

Table 12. Cumulative Energy Cost and Savings Over Time, Nominal \$, PPA

| | Do Nothing | PV PPA Financed | | | | |
|---------|-------------|-----------------|-----------------|--------------|------------|-----------|
| | Utility | Utility | Operating Costs | PPA Payments | \$ Savings | % Savings |
| Year 1 | \$718,000 | \$254,000 | \$8,000 | \$522,000 | \$(67,000) | -9% |
| Year 5 | \$808,000 | \$303,000 | \$8,000 | \$507,000 | \$(11,000) | -1% |
| Year 10 | \$937,000 | \$376,000 | \$1,000 | \$488,000 | \$72,000 | 8% |
| Year 15 | \$1,086,000 | \$463,000 | \$1,000 | \$470,000 | \$152,000 | 14% |
| Year 20 | \$1,259,000 | \$567,000 | \$1,000 | \$453,000 | \$239,000 | 19% |
| Year 25 | \$1,459,000 | \$882,000 | \$1,000 | \$436,000 | \$140,000 | 10% |

Figure 1 shows the annual energy cost through the 25-year design life, in nominal dollars, below. The notable step in the PPA line in year 20 is a result of loss of NEM 2.0.

Figure 2 shows the cumulative project savings, from construction through the 25-year design life, in nominal dollars.




Figure 1. Annual Energy Costs, Nominal Dollars




Figure 2. Cumulative Project Cash Flow, Nominal Dollars, PPA

3.5 Site-by-Site Analysis

Each system is priced individually, with smaller and/or more complex sites likely to receive higher PPA rates. Combining the PPA rates and the different utility tariffs by site, each site performs differently. As can be seen in Table 13, Marin ES and Ocean View ES are at risk of losing money over their lifetimes. This is due to these sites falling in between the other sites at the District: they are

smaller than the largest systems (and therefore have relatively high PPA rates), but have high enough demand to be billed at PG&E's medium tariff, which has lower energy savings than the smallest sites.

Table 13. Site-by-Site Analysis

| Site No. | Site | PPA Rate (\$/kWh) | 25-Year NPV (\$, 2.0% DR) |
|----------|-------------------|----------------------|------------------------------|
| 1 | Albany HS | \$0.256 | \$0.87 M |
| 2 | Albany MS | \$0.288 | \$0.19 M |
| 3 | Child Care Center | \$0.348 | \$0.10 M |
| 4 | Cornell ES | \$0.319 | \$0.36 M |
| 5 | Marin ES | \$0.304 | (\$0.03 M) |
| 6 | Ocean View ES | \$0.288 | (\$0.21 M) |
| | Total | \$0.280 | \$1.32 M |

If the District decides to move forward with an RFP, NV5 recommends re-evaluating each site with the vendor pricing to determine whether each site is likely to save money over the PPA term.

3.6 Sensitivity and Risk Analysis

NV5 conducted a sensitivity and risk analysis of the model parameters to assess the impacts of key project variables on the economic outcomes of projects. The results of this assessment have been included as Attachment C of this Report.

4. Key Points and Considerations

4.1 Key Points and Findings

Financing

- This study assesses PPA financing. Under a PPA arrangement, a third party finances, owns and operates the PV system, then sells electricity back to the District, typically under a 20- to 25-year agreement. PPA rates are estimated at Market Price (based on multiple other recent similar projects in California).
- Soft costs, such as consulting fees, IOR fees, purchase contingencies, legal and administrative fees, and special Inspection fees, are included in the upfront costs of the project. However, a PPA also allows for the possibility for these costs to be reimbursed by the PPA provider and recovered over the life of the contract in the form of a higher PPA rate.

PV Systems

- The project envisioned in this study would be constructed using a design-build-own-operate arrangement (PPA). The selected contractor would finance the project, be the designer of record, construct the project, then own and operate the facilities, selling power back to the District.
- All non-rooftop PV systems conceptualized in this study would be canopy-type structures, utilizing California DSA "Pre-Check" structures. The envisioned structures would be 12-foot minimum height, galvanized steel, "T" shaped structures. For all canopies in parking lots, the District may want to consider a minimum 14-foot height to avoid potential damage from trucks. The canopy consists of lighter weight metal purlins supporting a canopy of crystalline solar modules, with inverters hung on the columns. The procurement for the PV and electrical equipment would require mainstream equipment, from proven product lines and industry standard warranties.
- For rooftop PV systems, NV5 typically recommends mounting rooftop arrays on racking at a 5- or 10-degree tilt, depending on space constraints. At Marin ES, the architect has proposed flush-mounted panels (functionally 1-degree tilt) in order to maximize the size of the array. NV5 would not recommend this for two reasons: (1) our modeling shows that there is enough room on the rooftops to meet the desired energy production with 5-degree racking; (2) flush-mounted arrays have reduced performance due to high soiling, as water does not easily flow down the panels. Our experience has shown that many vendors also do not favor this approach, leading them to either avoid bidding on flush-mounted systems, increasing their price, or excluding those systems from their Production Guarantee (PeGu). For these reasons we recommend the layouts used for the RFP be based on 5-degree tilt racking.
- Siting of the proposed facilities carefully considered optimal production for each site, stakeholder input, and site constraints, such as fire lanes and future construction.

- System sizing targeted 80-85% usage offset (as established during the Desktop Feasibility Review), but with an understanding that exceeding this target (up to 100% offset) is acceptable to the District where financially efficient.

Ancillary Benefits

- The proposed solar project would offset 150 tons of CO₂ per year and 3,700 tons during the project lifetime.
- The RFP will require that the District keep all environmental attributes associated with the power produced. The environmental attributes of the energy generated, often referred to as Renewable Energy Credits (RECs) do have some value. The RECs can be sold on the market to generate additional income.
- The proposed project would add approximately 38,000 square feet of shade throughout the District. This report does not establish a monetary value for this shade, however shade projects are common public school capital projects. This project should eliminate some of the need to construct shade at District sites, saving capital project funds.

4.2 Schedule

The implementation of the two-phase project outlined in this study should take approximately 18 to 24 months to complete, from issuance of an RFP to solar PV Complete Construction and Project Closeout. The high-level implementation schedule in Table 14 shows the key milestones for implementing a PV system at the nine sites.

Table 14. Illustrative Timeline to Implementation

| Phase | Duration (months) | Cumulative (months) |
|----------------------------------|-------------------|---------------------|
| RFP Preparation/Vendor Proposals | 2 | 2 |
| Proposal Review/Contracting | 2 | 4 |
| Design & OTC DSA Process | 5 | 9 |
| Construction | 5 | 14 |
| Commissioning & Closeout | 3 | 17 |

Note: DSA closeout typically extends for several months beyond the end date shown.

Geotechnical

Geotechnical studies are key to the design of the canopy structures envisioned in this report. Soil classification and geohazard zones (such as areas at risk of liquefaction) can greatly increase the cost of canopy structures. For sites within a California Geologic Survey (CGS) classified hazard zone, we

often recommend geotechnical investigations be performed by the District before the RFP so the details can be included in the RFP release.

No geotechnical investigations were performed as part of this feasibility study. This approach also ensures that the designer of record is directing geotechnical investigations that will be the basis of their proposed design. We do recommend that any past geotechnical investigations from the sites be included in the RFP where available to assist in preparation of proposals. The risk in this approach is pushing off the discovery of issues which could impact the cost of a project. However, for the reasons stated above, this approach is advised for this project.

California Environmental Quality Act (CEQA)

CEQA requires state and local agencies (public agencies) to identify the significant environmental impacts of their actions and to avoid or mitigate them, if feasible. CEQA does apply to solar PV projects. There are CEQA statutory exemptions for solar PV constructed in parking lots and rooftops, which will apply to the sites outlined in this report. In most other cases, a categorical exemption would likely be pursued, since most other sites include canopies on hardscape play areas or at the edges of hardscape.

Authority Having Jurisdiction (AHJ)

The AHJs to consider for this project include:

1. DSA
2. Albany Fire Department

The DSA is the primary permitting agency for these projects. For all DSA sites, the RFP will require DSA Pre-Check (PC) structures to streamline permitting. The RFP will also require substantial California DSA experience from proposers to ensure familiarity with DSA's specific requirements.

DSA requires fire department review from the relevant jurisdictions. AUSD's facilities are all located in Albany, so review from a single department is likely to be sufficient.

Stakeholders

A project like this has several stakeholders, some of which would require approval, such as the District's Board, site representatives, AHJ, interested parties under CEQA, PG&E, and the public. Site stakeholders and the Board have become aware of the project through the process to date and should continue to be kept aware of the project. AHJs and interested parties will be notified through the course of implementing the project. The public should be engaged early in the process to minimize surprises and delays. NV5 and the selected contractor can assist the District with public meetings and engagement.

Electrical Infrastructure

Generation projects need to be tied into the existing electrical infrastructure at the site. To complete this process, upgrades to the customer or utility-side infrastructure may be required. Transformer

sizes have not been verified and impact on electrical switchgear has not been reviewed. Available information will be provided to proposers and a pre-proposal site walk will be arranged as part of the RFP.

Because all systems are under 1 MW-CEC-AC, they will all avoid costly metering requirements from PG&E for projects above that size as well as costs for utility-side upgrades.

Future Site Plans

The District provided input on future use plans during the assessment phase of the project, including details of ongoing construction at Marin ES, recently completed construction at Ocean View ES, and planned LED lighting retrofits at the other four sites. Any conceptual designs of other future plans should be provided to the selected contractor.

Electric Vehicle (EV) Charging

EV charging infrastructure is a growing consideration for parking areas. At a minimum, NV5 recommends that PV projects with structures in parking areas include spare conduits for future EV charging. Increasingly, EV chargers are being included in NV5's RFPs as an Additive Alternative to consider inclusion in PV projects. Additionally, EV buses are being implemented by Districts in California, which have more significant load and charging considerations. EV infrastructure should be discussed at the time of RFP preparation.

Hazardous Waste Consideration

In October 2015 California passed legislation that authorized the California Department of Toxic Substances Control to adopt regulations to designate end-of-life PV modules that are identified as hazardous waste as a universal waste and subject those modules to universal waste management. These new regulations were recently finalized and as of January 1, 2021, PV solar panels can be managed as universal waste.

PV modules have an expected life of 25 years, will have to be disposed of at the end of the project life. To budget for this future expense, a decommissioning reserve should be established for future removal and disposal of equipment, if the system is purchased by the District. Under a PPA, the system owner would be responsible for decommissioning the system at the end of the term.

Attachment A. 25-Year Financial Model Summary

1. 25-Year Financial Summary – PPA
2. Cash Flow Table – PPA

Project Information

| | | |
|------------------------------|-------------|------------|
| Number of Sites | Sites | 6 |
| Solar PV System Size | kW-DC | 1,258.40 |
| Solar PV Year 1 Production | kWh | 1,863,000 |
| Solar PV Yield | kWh/kW/Year | 1,480 |
| Modeled System Lifetime | Years | 25 |
| Solar PV Lifetime Production | kWh | 42,605,000 |

Electricity Usage Information

| | | |
|--------------------------------|---------------------|-----------|
| Annual Electricity Consumption | kWh | 2,159,000 |
| Annual Electricity Cost | \$, Current Tariffs | \$718,000 |
| Average Cost of Electricity | \$/kWh | \$0.3228 |

Financial Information

| | | |
|-------------------------------|--------|-------------|
| Turnkey Project Cost | \$ | \$8,178,000 |
| Project Soft Costs | \$ | \$180,000 |
| PPA Price, PV | \$/kWh | \$0.2804 |
| PPA Price Escalator | % | 0% |
| PPA Term | Years | 25 |
| Annual Utility Inflation Rate | % | 3.00% |
| NPV Discount Rate | % | 2.00% |

Financial Results

Year 1

| | | |
|--------------------------------|--------|-----------|
| Value of Solar, per kWh | \$/kWh | \$0.2491 |
| Value of Solar | \$ | \$464,000 |
| Annual Energy Cost After Solar | \$ | \$254,000 |
| Annual Operating Cost | \$ | \$8,000 |

25-year P50 Results, Solar PV

| | | |
|---------------------------|-------|-------------|
| Simple Payback, Solar | Years | 11.8 |
| Nominal Returns, Solar | \$ | \$1,994,000 |
| NPV Returns, 2% DR, Solar | \$ | \$1,323,000 |

Environmental Impacts

| | | |
|--------------------------------|----------------|--------|
| CO2e Offset per Year (Average) | Tonnes CO2e | 148 |
| CO2e Offset 25-year Total | Tonnes CO2e | 3,700 |
| Equivalent Cars | Cars per Year | 29 |
| Equivalent Trees Planted | Trees per Year | 32,607 |
| Equivalent Acres of Trees | Acres per Year | 63 |

Other Benefits


| | | |
|-----------------------------------|------|--------|
| Lifetime Renewable Energy Credits | RECs | 42,605 |
| Shade from Canopy Structures | SF | 38,385 |

Cash Flow Analysis of Solar PPA, PV Only

Albany USD, 6 Sites, May 18 2023

| PV | | | | | | | |
|------|-------------------------------|--------------------------------------|---------------------------|--------------------|--------------|--------------------|------------------------------|
| A | B | C | D | E | G | H | I |
| Year | Estimated Utility Usage (kWh) | Annual Estimated Utility Cost w/o PV | Utility Energy Cost w/ PV | PV Operating Costs | PPA Payments | Net Annual Savings | Cumulative Project Cash Flow |
| 0 | - | \$ - | \$ - | \$ - | \$ - | \$ (180,000) | \$ (180,000) |
| 1 | 2,159,000 | \$ 718,000 | \$ 254,000 | \$ 8,000 | \$ 522,000 | \$ (67,000) | \$ (247,000) |
| 2 | 2,159,000 | \$ 739,000 | \$ 265,000 | \$ 8,000 | \$ 518,000 | \$ (53,000) | \$ (300,000) |
| 3 | 2,159,000 | \$ 762,000 | \$ 278,000 | \$ 8,000 | \$ 514,000 | \$ (39,000) | \$ (339,000) |
| 4 | 2,159,000 | \$ 785,000 | \$ 291,000 | \$ 8,000 | \$ 511,000 | \$ (25,000) | \$ (364,000) |
| 5 | 2,159,000 | \$ 808,000 | \$ 303,000 | \$ 8,000 | \$ 507,000 | \$ (11,000) | \$ (375,000) |
| 6 | 2,159,000 | \$ 832,000 | \$ 317,000 | \$ 1,000 | \$ 503,000 | \$ 12,000 | \$ (363,000) |
| 7 | 2,159,000 | \$ 857,000 | \$ 331,000 | \$ 1,000 | \$ 499,000 | \$ 26,000 | \$ (337,000) |
| 8 | 2,159,000 | \$ 883,000 | \$ 346,000 | \$ 1,000 | \$ 495,000 | \$ 41,000 | \$ (296,000) |
| 9 | 2,159,000 | \$ 909,000 | \$ 360,000 | \$ 1,000 | \$ 492,000 | \$ 56,000 | \$ (240,000) |
| 10 | 2,159,000 | \$ 937,000 | \$ 376,000 | \$ 1,000 | \$ 488,000 | \$ 72,000 | \$ (168,000) |
| 11 | 2,159,000 | \$ 965,000 | \$ 392,000 | \$ 1,000 | \$ 484,000 | \$ 87,000 | \$ (81,000) |
| 12 | 2,159,000 | \$ 994,000 | \$ 409,000 | \$ 1,000 | \$ 481,000 | \$ 103,000 | \$ 22,000 |
| 13 | 2,159,000 | \$ 1,024,000 | \$ 427,000 | \$ 1,000 | \$ 477,000 | \$ 119,000 | \$ 141,000 |
| 14 | 2,159,000 | \$ 1,054,000 | \$ 444,000 | \$ 1,000 | \$ 474,000 | \$ 135,000 | \$ 276,000 |
| 15 | 2,159,000 | \$ 1,086,000 | \$ 463,000 | \$ 1,000 | \$ 470,000 | \$ 152,000 | \$ 428,000 |
| 16 | 2,159,000 | \$ 1,119,000 | \$ 483,000 | \$ 1,000 | \$ 467,000 | \$ 169,000 | \$ 597,000 |
| 17 | 2,159,000 | \$ 1,152,000 | \$ 502,000 | \$ 1,000 | \$ 463,000 | \$ 186,000 | \$ 783,000 |
| 18 | 2,159,000 | \$ 1,187,000 | \$ 523,000 | \$ 1,000 | \$ 460,000 | \$ 203,000 | \$ 986,000 |
| 19 | 2,159,000 | \$ 1,222,000 | \$ 544,000 | \$ 1,000 | \$ 456,000 | \$ 221,000 | \$ 1,207,000 |
| 20 | 2,159,000 | \$ 1,259,000 | \$ 567,000 | \$ 1,000 | \$ 453,000 | \$ 239,000 | \$ 1,446,000 |
| 21 | 2,159,000 | \$ 1,297,000 | \$ 767,000 | \$ 1,000 | \$ 449,000 | \$ 80,000 | \$ 1,526,000 |
| 22 | 2,159,000 | \$ 1,336,000 | \$ 794,000 | \$ 1,000 | \$ 446,000 | \$ 95,000 | \$ 1,621,000 |
| 23 | 2,159,000 | \$ 1,376,000 | \$ 823,000 | \$ 1,000 | \$ 443,000 | \$ 109,000 | \$ 1,730,000 |
| 24 | 2,159,000 | \$ 1,417,000 | \$ 852,000 | \$ 1,000 | \$ 439,000 | \$ 124,000 | \$ 1,854,000 |
| 25 | 2,159,000 | \$ 1,459,000 | \$ 882,000 | \$ 1,000 | \$ 436,000 | \$ 140,000 | \$ 1,994,000 |

PPA Cumulative Cash Flow, Nominal \$, PV Only






Attachment B. Annual Production Reports

Albany HS_2023-04-07_Feasibility

Albany USD, 603 Key Route Blvd, Albany, CA 94706

| Report | |
|---------------------|--|
| Project Name | Albany USD |
| Project Description | Jordan Bowen |
| Project Address | 603 Key Route Blvd, Albany, CA 94706 |
| Prepared By | Brent Johnson brent.johnson@nv5.com |


| System Metrics | |
|-----------------------|--|
| Design | Albany HS_2023-04-07_Feasibility |
| Module DC Nameplate | 530.6 kW |
| Inverter AC Nameplate | 453.2 kW Load Ratio: 1.17 |
| Annual Production | 791.8 MWh |
| Performance Ratio | 83.5% |
| kWh/kWp | 1,492.4 |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) |
| Simulator Version | e50a249196-410ce4a526-a9bd6d3cdf-c317fe4c80 |




| ⚡ Annual Production | | | |
|-----------------------------|-------------------------------------|-----------|---------|
| | Description | Output | % Delta |
| Irradiance (kWh/m²) | Annual Global Horizontal Irradiance | 1,691.6 | |
| | POA Irradiance | 1,786.9 | 5.6% |
| | Shaded Irradiance | 1,778.9 | -0.4% |
| | Irradiance after Reflection | 1,720.8 | -3.3% |
| | Irradiance after Soiling | 1,652.0 | -4.0% |
| | Total Collector Irradiance | 1,652.0 | 0.0% |
| Energy (kWh) | Nameplate | 890,516.7 | |
| | Output at Irradiance Levels | 886,414.7 | -0.5% |
| | Output at Cell Temperature Derate | 841,491.8 | -5.1% |
| | Output After Mismatch | 840,761.8 | -0.1% |
| | Optimizer Output | 828,987.2 | -1.4% |
| | Optimal DC Output | 826,820.5 | -0.3% |
| | Constrained DC Output | 816,248.0 | -1.3% |
| | Inverter Output | 803,854.9 | -1.5% |
| | Energy to Grid | 791,797.1 | -1.5% |
| Temperature Metrics | | | |
| Avg. Operating Ambient Temp | | 15.8 °C | |
| Avg. Operating Cell Temp | | 29.9 °C | |
| Simulation Metrics | | | |
| Operating Hours | | 4366 | |
| Solved Hours | | 4366 | |

| 📦 Components | | |
|--------------|-------------------------------|------------------|
| Component | Name | Count |
| Inverters | SE33.3KUS (2021) (SolarEdge) | 4 (133.2 kW) |
| Inverters | SE40KUS (2021) (SolarEdge) | 8 (320.0 kW) |
| Combiners | 1 input Combiner | 12 |
| Combiners | 2 input Combiner | 2 |
| Combiners | 3 input Combiner | 6 |
| Combiners | 4 input Combiner | 4 |
| Strings | 10 AWG (Copper) | 38 (2,986.2 ft) |
| Optimizers | P960 NA (2021) (SolarEdge) | 605 (580.8 kW) |
| Module | LG, LG450N2W-E6 (2021) (450W) | 1,179 (530.6 kW) |

| ☁ Condition Set | | | | | | | | | | | | |
|------------------------------|---|-------|---|---------|---|-------------------|-------------|----------------------------------|---|------------------|---|---|
| Description | TMY Oakland, 4 Soiling, 0-3 Mismatch, 1.5 AC Loss | | | | | | | | | | | |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) | | | | | | | | | | | |
| Solar Angle Location | Meteo Lat/Lng | | | | | | | | | | | |
| Transposition Model | Perez Model | | | | | | | | | | | |
| Temperature Model | Sandia Model | | | | | | | | | | | |
| Temperature Model Parameters | Rack Type | a | | b | | Temperature Delta | | | | | | |
| | Fixed Tilt | -3.56 | | -0.075 | | 3°C | | | | | | |
| | Flush Mount | -2.81 | | -0.0455 | | 0°C | | | | | | |
| Soiling (%) | J | F | M | A | M | J | J | A | S | O | N | D |
| | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| Irradiation Variance | 5% | | | | | | | | | | | |
| Cell Temperature Spread | 4° C | | | | | | | | | | | |
| Module Binning Range | 0% to 3% | | | | | | | | | | | |
| AC System Derate | 1.50% | | | | | | | | | | | |
| Trackers | Maximum Angle | | | | | | | Backtracking | | | | |
| | 60° | | | | | | | Enabled | | | | |
| Module Characterizations | Module | | | | | Uploaded By | | Characterization | | | | |
| | LG450N2W-E6 (2021) (LG) | | | | | HelioScope | | Spec Sheet Characterization, PAN | | | | |
| Component Characterizations | Device | | | | | | Uploaded By | | | Characterization | | |
| | SE33.3KUS (2021) (SolarEdge) | | | | | | HelioScope | | | Spec Sheet | | |
| | SE40KUS (2021) (SolarEdge) | | | | | | HelioScope | | | Spec Sheet | | |
| | P960 NA (2021) (SolarEdge) | | | | | | HelioScope | | | Mfg Spec Sheet | | |

|  Wiring Zones | | | |
|--|----------------|-------------|--------------------|
| Description | Combiner Poles | String Size | Stringing Strategy |
| Wiring Zone | 12 | 13-34 | Along Racking |
| Wiring Zone 2 | 12 | 13-34 | Along Racking |
| Wiring Zone 3 | 12 | 13-34 | Along Racking |
| Wiring Zone 4 | 12 | 13-34 | Along Racking |
| Wiring Zone 5 | 12 | 13-34 | Along Racking |
| Wiring Zone 6 | 12 | 13-34 | Along Racking |
| Wiring Zone 7 | 12 | 13-34 | Along Racking |

|  Field Segments | | | | | | | | | |
|--|-------------|------------------------|------|------------|------------------|------------|--------|---------|----------|
| Description | Racking | Orientation | Tilt | Azimuth | Intrarow Spacing | Frame Size | Frames | Modules | Power |
| R-1 | Fixed Tilt | Landscape (Horizontal) | 8° | 182.19933° | 1.3 ft | 1x1 | 208 | 208 | 93.6 kW |
| R-2 | Fixed Tilt | Landscape (Horizontal) | 8° | 181.83554° | 1.3 ft | 1x1 | 231 | 231 | 104.0 kW |
| R-4 | Fixed Tilt | Landscape (Horizontal) | 8° | 181.83554° | 1.3 ft | 1x1 | 69 | 69 | 31.1 kW |
| R-5 | Flush Mount | Portrait (Vertical) | 8° | 181.83554° | 0.0 ft | 1x1 | 231 | 231 | 104.0 kW |
| R-7 | Flush Mount | Portrait (Vertical) | 8° | 181.83554° | 0.0 ft | 1x1 | 70 | 70 | 31.5 kW |
| R-6 | Flush Mount | Landscape (Horizontal) | 8° | 181.83554° | 0.0 ft | 1x1 | 30 | 30 | 13.5 kW |
| R-3 | Flush Mount | Portrait (Vertical) | 5° | 181.83554° | 0.0 ft | 1x1 | 216 | 216 | 97.2 kW |
| R-9 (Solar Ready) | Flush Mount | Landscape (Horizontal) | 10° | 182.10313° | 0.0 ft | 1x1 | 52 | 52 | 23.4 kW |
| R-8 (Solar Ready) | Flush Mount | Landscape (Horizontal) | 10° | 181.95895° | 0.0 ft | 1x1 | 72 | 72 | 32.4 kW |

 Detailed Layout






Albany MS_2023-04-07_Feasibility

Albany USD, 1259 Brighton Ave, Albany, CA 94706

| Report | |
|---------------------|--|
| Project Name | Albany USD |
| Project Description | Jordan Bowen |
| Project Address | 1259 Brighton Ave, Albany, CA 94706 |
| Prepared By | Brent Johnson brent.johnson@nv5.com |

| System Metrics | |
|-----------------------|--|
| Design | Albany MS_2023-04-07_Feasibility |
| Module DC Nameplate | 223.6 kW |
| Inverter AC Nameplate | 180.0 kW Load Ratio: 1.24 |
| Annual Production | 334.3 MWh |
| Performance Ratio | 84.0% |
| kWh/kWp | 1,495.3 |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) |
| Simulator Version | 28179409b0-e97228905f-dee8ce9e64-bbf3497f23 |



| ⚡ Annual Production | | | |
|-----------------------------|-------------------------------------|-----------|---------|
| | Description | Output | % Delta |
| Irradiance (kWh/m²) | Annual Global Horizontal Irradiance | 1,691.6 | |
| | POA Irradiance | 1,779.4 | 5.2% |
| | Shaded Irradiance | 1,778.8 | 0.0% |
| | Irradiance after Reflection | 1,718.6 | -3.4% |
| | Irradiance after Soiling | 1,649.8 | -4.0% |
| | Total Collector Irradiance | 1,649.8 | 0.0% |
| Energy (kWh) | Nameplate | 374,419.6 | |
| | Output at Irradiance Levels | 372,561.4 | -0.5% |
| | Output at Cell Temperature Derate | 364,236.6 | -2.2% |
| | Output After Mismatch | 351,146.6 | -3.6% |
| | Optimal DC Output | 350,593.4 | -0.2% |
| | Constrained DC Output | 349,071.6 | -0.4% |
| | Inverter Output | 339,390.0 | -2.8% |
| | Energy to Grid | 334,299.2 | -1.5% |
| Temperature Metrics | | | |
| Avg. Operating Ambient Temp | | 15.8 °C | |
| Avg. Operating Cell Temp | | 24.4 °C | |
| Simulation Metrics | | | |
| Operating Hours | | 4366 | |
| Solved Hours | | 4366 | |

| ☁ Condition Set | | | | | | | | | | | | |
|------------------------------|---|-------|---|---------|---|-------------------|-------------|----------------------------------|--------------------------|---|---|---|
| Description | TMY Oakland, 4 Soiling, 0-3 Mismatch, 1.5 AC Loss | | | | | | | | | | | |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) | | | | | | | | | | | |
| Solar Angle Location | Meteo Lat/Lng | | | | | | | | | | | |
| Transposition Model | Perez Model | | | | | | | | | | | |
| Temperature Model | Sandia Model | | | | | | | | | | | |
| Temperature Model Parameters | Rack Type | a | | b | | Temperature Delta | | | | | | |
| | Fixed Tilt | -3.56 | | -0.075 | | 3°C | | | | | | |
| | Flush Mount | -2.81 | | -0.0455 | | 0°C | | | | | | |
| Soiling (%) | J | F | M | A | M | J | J | A | S | O | N | D |
| | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| Irradiation Variance | 5% | | | | | | | | | | | |
| Cell Temperature Spread | 4° C | | | | | | | | | | | |
| Module Binning Range | 0% to 3% | | | | | | | | | | | |
| AC System Derate | 1.50% | | | | | | | | | | | |
| Trackers | Maximum Angle | | | | | | | Backtracking | | | | |
| | 60° | | | | | | | Enabled | | | | |
| Module Characterizations | Module | | | | | Uploaded By | | Characterization | | | | |
| | LR4-72HPH-460M (Longi Solar) | | | | | HelioScope | | Spec Sheet Characterization, PAN | | | | |
| Component Characterizations | Device | | | | | | Uploaded By | | Characterization | | | |
| | CPS SC20KTL-DO (Shanghai Chint Power Systems) | | | | | | HelioScope | | Default Characterization | | | |

| 📦 Components | | |
|--------------|---|-----------------|
| Component | Name | Count |
| Inverters | CPS SC20KTL-DO (Shanghai Chint Power Systems) | 9 (180.0 kW) |
| Strings | 10 AWG (Copper) | 27 (1,511.0 ft) |
| Module | Longi Solar, LR4-72HPH-460M (460W) | 486 (223.6 kW) |

| 🔌 Wiring Zones | | | |
|----------------|----------------|-------------|--------------------|
| Description | Combiner Poles | String Size | Stringing Strategy |
| Wiring Zone | - | 13-18 | Along Racking |

| 🏠 Field Segments | | | | | | | | | |
|------------------|---------|---------------------|------|------------|------------------|------------|--------|---------|----------|
| Description | Racking | Orientation | Tilt | Azimuth | Intrarow Spacing | Frame Size | Frames | Modules | Power |
| C-1 | Carport | Portrait (Vertical) | 7° | 196.11949° | 0.0 ft | 6x1 | 43 | 258 | 118.7 kW |
| C-2 | Carport | Portrait (Vertical) | 7° | 196.11949° | 0.0 ft | 6x1 | 38 | 228 | 104.9 kW |




 Detailed Layout



Child Care Center 2023-04-07 Feasibility Albany USD, 720 Jackson St, Albany, CA 94706

| Report | |
|---------------------|--|
| Project Name | Albany USD |
| Project Description | Jordan Bowen |
| Project Address | 720 Jackson St, Albany, CA 94706 |
| Prepared By | Brent Johnson brent.johnson@nv5.com |

| System Metrics | |
|-----------------------|--|
| Design | Child Care Center 2023-04-07 Feasibility |
| Module DC Nameplate | 44.2 kW |
| Inverter AC Nameplate | 40.0 kW Load Ratio: 1.10 |
| Annual Production | 64.41 MWh |
| Performance Ratio | 84.7% |
| kWh/kWp | 1,458.5 |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) |
| Simulator Version | e50a249196-410ce4a526-a9bd6d3cdf-c317fe4c80 |



| ⚡ Annual Production | | | |
|-----------------------------|-------------------------------------|----------|---------|
| | Description | Output | % Delta |
| Irradiance (kWh/m²) | Annual Global Horizontal Irradiance | 1,691.6 | |
| | POA Irradiance | 1,721.5 | 1.8% |
| | Shaded Irradiance | 1,721.5 | 0.0% |
| | Irradiance after Reflection | 1,660.2 | -3.6% |
| | Irradiance after Soiling | 1,593.8 | -4.0% |
| | Total Collector Irradiance | 1,593.8 | 0.0% |
| Energy (kWh) | Nameplate | 71,447.3 | |
| | Output at Irradiance Levels | 71,058.8 | -0.5% |
| | Output at Cell Temperature Derate | 69,569.4 | -2.1% |
| | Output After Mismatch | 67,253.8 | -3.3% |
| | Optimal DC Output | 67,158.1 | -0.1% |
| | Constrained DC Output | 67,157.1 | 0.0% |
| | Inverter Output | 65,389.3 | -2.6% |
| | Energy to Grid | 64,408.4 | -1.5% |
| Temperature Metrics | | | |
| Avg. Operating Ambient Temp | | 15.8 °C | |
| Avg. Operating Cell Temp | | 24.1 °C | |
| Simulation Metrics | | | |
| Operating Hours | | | 4366 |
| Solved Hours | | | 4366 |

| ☁ Condition Set | | | | | | | | | | | | |
|------------------------------|---|-------|---|---------|---|-------------------|-------------|----------------------------------|--------------------------|---|---|---|
| Description | TMY Oakland, 4 Soiling, 0-3 Mismatch, 1.5 AC Loss | | | | | | | | | | | |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) | | | | | | | | | | | |
| Solar Angle Location | Meteo Lat/Lng | | | | | | | | | | | |
| Transposition Model | Perez Model | | | | | | | | | | | |
| Temperature Model | Sandia Model | | | | | | | | | | | |
| Temperature Model Parameters | Rack Type | a | | b | | Temperature Delta | | | | | | |
| | Fixed Tilt | -3.56 | | -0.075 | | 3°C | | | | | | |
| | Flush Mount | -2.81 | | -0.0455 | | 0°C | | | | | | |
| Soiling (%) | J | F | M | A | M | J | J | A | S | O | N | D |
| | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| Irradiation Variance | 5% | | | | | | | | | | | |
| Cell Temperature Spread | 4° C | | | | | | | | | | | |
| Module Binning Range | 0% to 3% | | | | | | | | | | | |
| AC System Derate | 1.50% | | | | | | | | | | | |
| Trackers | Maximum Angle | | | | | | | Backtracking | | | | |
| | 60° | | | | | | | Enabled | | | | |
| Module Characterizations | Module | | | | | Uploaded By | | Characterization | | | | |
| | LR4-72HPH-460M (Longi Solar) | | | | | HelioScope | | Spec Sheet Characterization, PAN | | | | |
| Component Characterizations | Device | | | | | | Uploaded By | | Characterization | | | |
| | CPS SC20KTL-DO (Shanghai Chint Power Systems) | | | | | | HelioScope | | Default Characterization | | | |

| 📦 Components | | |
|--------------|---|--------------|
| Component | Name | Count |
| Inverters | CPS SC20KTL-DO (Shanghai Chint Power Systems) | 2 (40.0 kW) |
| Strings | 10 AWG (Copper) | 6 (241.7 ft) |
| Module | Longi Solar, LR4-72HPH-460M (460W) | 96 (44.2 kW) |

| 🔌 Wiring Zones | | | |
|----------------|----------------|-------------|--------------------|
| Description | Combiner Poles | String Size | Stringing Strategy |
| Wiring Zone | - | 13-18 | Along Racking |

| 🏠 Field Segments | | | | | | | | | | |
|------------------|---------|---------------------|------|---------|------------------|------------|--------|---------|---------|--|
| Description | Racking | Orientation | Tilt | Azimuth | Intrarow Spacing | Frame Size | Frames | Modules | Power | |
| C1 | Carport | Portrait (Vertical) | 7° | 257° | 0.0 ft | 6x1 | 16 | 96 | 44.2 kW | |




 Detailed Layout



Cornell ES_2023-04-07 Feasibility Albany USD, 920 Talbot Ave, Albany, CA 94706

| Report | |
|---------------------|--|
| Project Name | Albany USD |
| Project Description | Jordan Bowen |
| Project Address | 920 Talbot Ave, Albany, CA 94706 |
| Prepared By | Brent Johnson brent.johnson@nv5.com |

| System Metrics | |
|-----------------------|--|
| Design | Cornell ES_2022-04-07 Feasibility |
| Module DC Nameplate | 96.8 kW |
| Inverter AC Nameplate | 100.0 kW Load Ratio: 0.97 |
| Annual Production | 141.5 MWh |
| Performance Ratio | 84.8% |
| kWh/kWp | 1,462.7 |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) |
| Simulator Version | e50a249196-410ce4a526-a9bd6d3cdf-c317fe4c80 |




| ⚡ Annual Production | | | |
|-----------------------------|-------------------------------------|-----------|---------|
| | Description | Output | % Delta |
| Irradiance (kWh/m²) | Annual Global Horizontal Irradiance | 1,691.6 | |
| | POA Irradiance | 1,724.9 | 2.0% |
| | Shaded Irradiance | 1,723.5 | -0.1% |
| | Irradiance after Reflection | 1,662.4 | -3.5% |
| | Irradiance after Soiling | 1,595.9 | -4.0% |
| | Total Collector Irradiance | 1,595.9 | 0.0% |
| Energy (kWh) | Nameplate | 156,884.8 | |
| | Output at Irradiance Levels | 156,105.9 | -0.5% |
| | Output at Cell Temperature Derate | 153,036.5 | -2.0% |
| | Output After Mismatch | 147,142.4 | -3.9% |
| | Optimal DC Output | 146,902.8 | -0.2% |
| | Constrained DC Output | 146,900.4 | 0.0% |
| | Inverter Output | 143,668.6 | -2.2% |
| | Energy to Grid | 141,513.6 | -1.5% |
| Temperature Metrics | | | |
| Avg. Operating Ambient Temp | | 15.8 °C | |
| Avg. Operating Cell Temp | | 24.1 °C | |
| Simulation Metrics | | | |
| Operating Hours | | 4366 | |
| Solved Hours | | 4366 | |

| ☁ Condition Set | | | | | | | | | | | | |
|------------------------------|---|---|-------|---|-------------|---|-------------------|----------------------------------|---|------------------|---|---|
| Description | TMY Oakland, 4 Soiling, 0-3 Mismatch, 1.5 AC Loss | | | | | | | | | | | |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) | | | | | | | | | | | |
| Solar Angle Location | Meteo Lat/Lng | | | | | | | | | | | |
| Transposition Model | Perez Model | | | | | | | | | | | |
| Temperature Model | Sandia Model | | | | | | | | | | | |
| Temperature Model Parameters | Rack Type | | a | | b | | Temperature Delta | | | | | |
| | Fixed Tilt | | -3.56 | | -0.075 | | 3°C | | | | | |
| | Flush Mount | | -2.81 | | -0.0455 | | 0°C | | | | | |
| Soiling (%) | J | F | M | A | M | J | J | A | S | O | N | D |
| | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| Irradiation Variance | 5% | | | | | | | | | | | |
| Cell Temperature Spread | 4° C | | | | | | | | | | | |
| Module Binning Range | 0% to 3% | | | | | | | | | | | |
| AC System Derate | 1.50% | | | | | | | | | | | |
| Trackers | Maximum Angle | | | | | | | Backtracking | | | | |
| | 60° | | | | | | | Enabled | | | | |
| Module Characterizations | Module | | | | Uploaded By | | | Characterization | | | | |
| | LG450N2W-E6 (2021) (LG) | | | | HelioScope | | | Spec Sheet Characterization, PAN | | | | |
| Component Characterizations | Device | | | | | | Uploaded By | | | Characterization | | |
| | Sunny Tripower Core1 STP 50-41 (380V) (SMA) | | | | | | HelioScope | | | Spec Sheet | | |

| 📦 Components | | |
|--------------|---|---------------|
| Component | Name | Count |
| Inverters | Sunny Tripower Core1 STP 50-41 (380V) (SMA) | 2 (100.0 kW) |
| Home Runs | 2 AWG (Copper) | 3 (36.5 ft) |
| Home Runs | 500 MCM (Copper) | 3 (94.6 ft) |
| Combiners | 1 input Combiner | 3 |
| Combiners | 3 input Combiner | 1 |
| Combiners | 4 input Combiner | 1 |
| Combiners | 6 input Combiner | 1 |
| Strings | 10 AWG (Copper) | 13 (764.7 ft) |
| Module | LG, LG450N2W-E6 (2021) (450W) | 215 (96.8 kW) |

| 🔌 Wiring Zones | | | |
|----------------|----------------|-------------|--------------------|
| Description | Combiner Poles | String Size | Stringing Strategy |
| Wiring Zone | 12 | 13-19 | Along Racking |
| Wiring Zone 2 | 12 | - | Along Racking |




| 🏠 Field Segments | | | | | | | | | |
|------------------|---------|---------------------|------|-----------|------------------|------------|--------|---------|---------|
| Description | Racking | Orientation | Tilt | Azimuth | Intrarow Spacing | Frame Size | Frames | Modules | Power |
| C-1 | Carport | Portrait (Vertical) | 7.5° | 255.8542° | 1.3 ft | 5x1 | 26 | 130 | 58.5 kW |
| C-2 | Carport | Portrait (Vertical) | 7.5° | 255.8542° | 1.3 ft | 5x1 | 17 | 85 | 38.3 kW |



Marin ES_2023-04-07_Feasibility Albany USD, 1001 Santa Fe Ave, Albany, CA 94706

| Report | |
|---------------------|--|
| Project Name | Albany USD |
| Project Description | Jordan Bowen |
| Project Address | 1001 Santa Fe Ave, Albany, CA 94706 |
| Prepared By | Brent Johnson brent.johnson@nv5.com |

| System Metrics | |
|-----------------------|--|
| Design | Marin ES_2023-04-07_Feasibility |
| Module DC Nameplate | 143.1 kW |
| Inverter AC Nameplate | 120.0 kW Load Ratio: 1.19 |
| Annual Production | 208.0 MWh |
| Performance Ratio | 86.0% |
| kWh/kWp | 1,453.5 |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) |
| Simulator Version | e50a249196-410ce4a526-a9bd6d3cdf-c317fe4c80 |



| ⚡ Annual Production | | | |
|-----------------------------|-------------------------------------|-----------|---------|
| | Description | Output | % Delta |
| Irradiance (kWh/m²) | Annual Global Horizontal Irradiance | 1,691.6 | |
| | POA Irradiance | 1,691.1 | 0.0% |
| | Shaded Irradiance | 1,691.1 | 0.0% |
| | Irradiance after Reflection | 1,627.3 | -3.8% |
| | Irradiance after Soiling | 1,562.2 | -4.0% |
| | Total Collector Irradiance | 1,562.2 | 0.0% |
| Energy (kWh) | Nameplate | 227,143.7 | |
| | Output at Irradiance Levels | 225,946.8 | -0.5% |
| | Output at Cell Temperature Derate | 221,715.0 | -1.9% |
| | Output After Mismatch | 221,714.8 | 0.0% |
| | Optimizer Output | 218,610.5 | -1.4% |
| | Optimal DC Output | 218,397.0 | -0.1% |
| | Constrained DC Output | 214,426.2 | -1.8% |
| | Inverter Output | 211,162.8 | -1.5% |
| | Energy to Grid | 207,995.4 | -1.5% |
| Temperature Metrics | | | |
| Avg. Operating Ambient Temp | | 15.8 °C | |
| Avg. Operating Cell Temp | | 24.0 °C | |
| Simulation Metrics | | | |
| Operating Hours | | 4366 | |
| Solved Hours | | 4366 | |

| ☁ Condition Set | | | | | | | | | | | | |
|------------------------------|---|-------|---|---------|---|-------------------|-------------|----------------------------------|---|------------------|---|---|
| Description | TMY Oakland, 4 Soiling, 0-3 Mismatch, 1.5 AC Loss | | | | | | | | | | | |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) | | | | | | | | | | | |
| Solar Angle Location | Meteo Lat/Lng | | | | | | | | | | | |
| Transposition Model | Perez Model | | | | | | | | | | | |
| Temperature Model | Sandia Model | | | | | | | | | | | |
| Temperature Model Parameters | Rack Type | a | | b | | Temperature Delta | | | | | | |
| | Fixed Tilt | -3.56 | | -0.075 | | 3°C | | | | | | |
| | Flush Mount | -2.81 | | -0.0455 | | 0°C | | | | | | |
| Soiling (%) | J | F | M | A | M | J | J | A | S | O | N | D |
| | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| Irradiation Variance | 5% | | | | | | | | | | | |
| Cell Temperature Spread | 4° C | | | | | | | | | | | |
| Module Binning Range | 0% to 3% | | | | | | | | | | | |
| AC System Derate | 1.50% | | | | | | | | | | | |
| Trackers | Maximum Angle | | | | | | | Backtracking | | | | |
| | 60° | | | | | | | Enabled | | | | |
| Module Characterizations | Module | | | | | Uploaded By | | Characterization | | | | |
| | LG450N2W-E6 (2021) (LG) | | | | | HelioScope | | Spec Sheet Characterization, PAN | | | | |
| Component Characterizations | Device | | | | | | Uploaded By | | | Characterization | | |
| | SE40KUS (2021) (SolarEdge) | | | | | | HelioScope | | | Spec Sheet | | |
| | P960 NA (2021) (SolarEdge) | | | | | | HelioScope | | | Mfg Spec Sheet | | |

| 📦 Components | | |
|--------------|-------------------------------|----------------|
| Component | Name | Count |
| Inverters | SE40KUS (2021) (SolarEdge) | 3 (120.0 kW) |
| Combiners | 1 input Combiner | 3 |
| Combiners | 3 input Combiner | 2 |
| Combiners | 4 input Combiner | 1 |
| Strings | 10 AWG (Copper) | 10 (416.8 ft) |
| Optimizers | P960 NA (2021) (SolarEdge) | 318 (305.3 kW) |
| Module | LG, LG450N2W-E6 (2021) (450W) | 318 (143.1 kW) |

| 🔌 Wiring Zones | | | |
|----------------|----------------|-------------|---------------------|
| Description | Combiner Poles | String Size | Stringing Strategy |
| Wiring Zone | 12 | 13-34 | Up and Down Racking |

| 🏠 Field Segments | | | | | | | | | | |
|------------------|-------------|------------------------|------|------------|------------------|------------|--------|---------|---------|--|
| Description | Racking | Orientation | Tilt | Azimuth | Intrarow Spacing | Frame Size | Frames | Modules | Power | |
| Bldg D R1 | Fixed Tilt | Landscape (Horizontal) | 0° | 160° | 0.0 ft | 1x1 | 104 | 104 | 46.8 kW | |
| Bldg D R2 | Fixed Tilt | Landscape (Horizontal) | 0° | 155.25647° | 0.0 ft | 1x1 | 104 | 104 | 46.8 kW | |
| Bldg B R1 | Fixed Tilt | Landscape (Horizontal) | 0° | 106.65425° | 0.0 ft | 1x1 | 110 | 110 | 49.5 kW | |
| Field Segment 4 | Flush Mount | Landscape (Horizontal) | 7.5° | 106.65425° | 0.0 ft | 1x1 | | | 0 | |




 Detailed Layout



Ocean View ES_2023-04-07_Feasibility Albany USD, 1000 Jackson St, Albany, CA 94706

| Report | |
|---------------------|--|
| Project Name | Albany USD |
| Project Description | Jordan Bowen |
| Project Address | 1000 Jackson St, Albany, CA 94706 |
| Prepared By | Brent Johnson brent.johnson@nv5.com |

| System Metrics | |
|-----------------------|--|
| Design | Ocean View ES_2023-04-07_Feasibility |
| Module DC Nameplate | 220.1 kW |
| Inverter AC Nameplate | 229.6 kW Load Ratio: 0.96 |
| Annual Production | 322.6 MWh |
| Performance Ratio | 82.6% |
| kWh/kWp | 1,466.0 |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) |
| Simulator Version | e50a249196-410ce4a526-a9bd6d3cdf-c317fe4c80 |



| ⚡ Annual Production | | | |
|-----------------------------|-------------------------------------|-----------|---------|
| | Description | Output | % Delta |
| Irradiance (kWh/m²) | Annual Global Horizontal Irradiance | 1,691.6 | |
| | POA Irradiance | 1,775.6 | 5.0% |
| | Shaded Irradiance | 1,773.6 | -0.1% |
| | Irradiance after Reflection | 1,713.5 | -3.4% |
| | Irradiance after Soiling | 1,644.9 | -4.0% |
| | Total Collector Irradiance | 1,644.9 | 0.0% |
| Energy (kWh) | Nameplate | 367,766.5 | |
| | Output at Irradiance Levels | 366,050.7 | -0.5% |
| | Output at Cell Temperature Derate | 343,718.9 | -6.1% |
| | Output After Mismatch | 343,417.7 | -0.1% |
| | Optimizer Output | 338,607.3 | -1.4% |
| | Optimal DC Output | 337,698.5 | -0.3% |
| | Constrained DC Output | 337,634.7 | 0.0% |
| | Inverter Output | 327,505.7 | -3.0% |
| | Energy to Grid | 322,593.1 | -1.5% |
| Temperature Metrics | | | |
| Avg. Operating Ambient Temp | | 15.8 °C | |
| Avg. Operating Cell Temp | | 31.9 °C | |
| Simulation Metrics | | | |
| Operating Hours | | 4366 | |
| Solved Hours | | 4366 | |

| ☁ Condition Set | | | | | | | | | | | | |
|------------------------------|---|-------|---|---------|---|-------------------|-------------|----------------------------------|---|------------------|---|---|
| Description | TMY Oakland, 4 Soiling, 0-3 Mismatch, 1.5 AC Loss | | | | | | | | | | | |
| Weather Dataset | TMY, OAKLAND METROPOLITAN ARPT, NSRDB (tmy3, II) | | | | | | | | | | | |
| Solar Angle Location | Meteo Lat/Lng | | | | | | | | | | | |
| Transposition Model | Perez Model | | | | | | | | | | | |
| Temperature Model | Sandia Model | | | | | | | | | | | |
| Temperature Model Parameters | Rack Type | a | | b | | Temperature Delta | | | | | | |
| | Fixed Tilt | -3.56 | | -0.075 | | 3°C | | | | | | |
| | Flush Mount | -2.81 | | -0.0455 | | 0°C | | | | | | |
| Soiling (%) | J | F | M | A | M | J | J | A | S | O | N | D |
| | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| Irradiation Variance | 5% | | | | | | | | | | | |
| Cell Temperature Spread | 4° C | | | | | | | | | | | |
| Module Binning Range | 0% to 3% | | | | | | | | | | | |
| AC System Derate | 1.50% | | | | | | | | | | | |
| Trackers | Maximum Angle | | | | | | | Backtracking | | | | |
| | 60° | | | | | | | Enabled | | | | |
| Module Characterizations | Module | | | | | Uploaded By | | Characterization | | | | |
| | LG450N2W-E6 (2021) (LG) | | | | | HelioScope | | Spec Sheet Characterization, PAN | | | | |
| Component Characterizations | Device | | | | | | Uploaded By | | | Characterization | | |
| | SE43.2K (SolarEdge) | | | | | | HelioScope | | | Spec Sheet | | |
| | SE50KUS (SolarEdge) | | | | | | HelioScope | | | Spec Sheet | | |
| | SE14.4KUS (2021) (SolarEdge) | | | | | | HelioScope | | | Spec Sheet | | |
| | P960 NA (2021) (SolarEdge) | | | | | | HelioScope | | | Mfg Spec Sheet | | |

| 📦 Components | | |
|--------------|-------------------------------|-----------------|
| Component | Name | Count |
| Inverters | SE43.2K (SolarEdge) | 3 (129.6 kW) |
| Inverters | SE50KUS (SolarEdge) | 2 (100.0 kW) |
| Home Runs | 2 AWG (Copper) | 5 (111.7 ft) |
| Home Runs | 500 MCM (Copper) | 5 (73.2 ft) |
| Combiners | 1 input Combiner | 5 |
| Combiners | 5 input Combiner | 1 |
| Combiners | 6 input Combiner | 4 |
| Strings | 10 AWG (Copper) | 29 (2,035.6 ft) |
| Optimizers | P960 NA (2021) (SolarEdge) | 249 (239.0 kW) |
| Module | LG, LG450N2W-E6 (2021) (450W) | 489 (220.1 kW) |

| 🏠 Wiring Zones | | | |
|----------------|----------------|-------------|---------------------|
| Description | Combiner Poles | String Size | Stringing Strategy |
| Wiring Zone | 12 | 9-19 | Along Racking |
| Wiring Zone 2 | 12 | 7-16 | Along Racking |
| Wiring Zone 4 | 12 | 18-18 | Up and Down Racking |
| Wiring Zone 5 | 12 | - | Up and Down Racking |

| 🏠 Field Segments | | | | | | | | | |
|------------------|-------------|---------------------|------|------------|------------------|------------|--------|---------|---------|
| Description | Racking | Orientation | Tilt | Azimuth | Intrarow Spacing | Frame Size | Frames | Modules | Power |
| R1 | Flush Mount | Portrait (Vertical) | 7.1° | 176.83307° | 0.1 ft | 1x1 | 113 | 113 | 50.9 kW |
| R2 | Flush Mount | Portrait (Vertical) | 7.1° | 171.91855° | 0.1 ft | 1x1 | 120 | 120 | 54.0 kW |
| C-1 | Carport | Portrait (Vertical) | 7.5° | 172° | 0.0 ft | 5x1 | 22 | 108 | 48.6 kW |
| R2 (copy) | Flush Mount | Portrait (Vertical) | 7.1° | 171.91855° | 0.1 ft | 1x1 | 120 | 120 | 54.0 kW |
| R2 (copy 1) | Flush Mount | Portrait (Vertical) | 5° | 261.91855° | 0.0 ft | 1x1 | 14 | 14 | 6.30 kW |
| R2 (copy 2) | Flush Mount | Portrait (Vertical) | 5° | 261.91855° | 0.0 ft | 1x1 | 14 | 14 | 6.30 kW |

Detailed Layout



Attachment C. Sensitivity and Risk Analysis

Overview

The following summarizes the key project variables and results included in the sensitivity analysis.

The sensitivity and risk analysis helped assess the impacts of key project variables on the economic outcomes of projects by conducting a multivariable Monte Carlo simulation.

PPA

Table 15 shows how the NPV savings changes as each sensitivity parameter varies with optimistic, expected, and conservative assumptions.

Figure 3 shows the change in 25-year NPV savings for each of the sensitivity parameters with the highest impact on NPV savings. Figure 4 shows the 90% probability 25-year savings in nominal dollars when considering the 90% probability of all the sensitivity parameters. As shown in the chart, the 25-year NPV savings can vary by as much as \$2.6M depending on the parameter assumptions.

Table 15. Sensitivity Analysis \$ NPV Saving Variance Results, PPA

| Sensitivity Parameter | NPV Savings Results | | |
|---|---------------------|-----------------|-----------------|
| | Optimistic | Expected | Conservative |
| Utility Annual Energy Escalator | \$2.76 M | \$1.32 M | \$0.09 M |
| PPA Price w/Soft Costs, PV Only, \$/kWh | \$2.34 M | \$1.32 M | \$0.33 M |
| System Production Degradation per Year | \$1.42 M | \$1.32 M | \$1.23 M |
| Energy Value Change #2 (NEM 20-yr) | \$1.38 M | \$1.32 M | \$1.26 M |
| Tariff Rate Change Value Risk, per year | \$1.36 M | \$1.32 M | \$1.29 M |
| Installed System Cost | \$1.34 M | \$1.32 M | \$1.31 M |
| PPA Host Consultant Fees | \$1.34 M | \$1.32 M | \$1.31 M |
| PPA Host Testing and Inspection | \$1.34 M | \$1.32 M | \$1.31 M |
| Aggregate of All Variables | \$2.29 M | \$1.32 M | \$0.40 M |




Figure 3. Sensitivity Analysis Parameter Results, PPA




Figure 4. Cumulative Cash Flow, PPA

Attachment D. Acronym Glossary

Acronym Glossary

| | |
|-------------------|--|
| AHJ | Authority Having Jurisdiction. |
| ATS | Automatic Transfer Switch – device to automatically transfer load from a primary to secondary source of electrical power. |
| AUSD | Albany Unified School District – the project customer. |
| BESS | Battery Energy Storage System. |
| CCA | Community Choice Aggregator – local government entity that offers to sell electrical energy to local electric utility customers. |
| CEC-AC | Rating created by the California Energy Commission to approximate real-world production of a solar system. |
| CEQA | California Environmental Quality Act – state statute requiring public agencies to identify the significant environmental impacts of their actions and to avoid or mitigate them, if feasible. |
| CO ₂ e | Carbon Dioxide equivalent – environmental impact equivalent in metric tons. |
| CPUC | California Public Utilities Commission – regulatory agency in California that provides oversight to, among others, the electric power utilities in the state. |
| DSA | Division of the State Architect – California agency that provides design and construction oversight for public schools. |
| EBCE | East Bay Community Energy – a CCA providing energy to customers in Alameda County. |
| ETB | Energy Toolbase – a web-based tariff and energy storage modeling software tool. |
| IA | Interconnection Application/Agreement – process to connect a generation source (e.g., solar PV) to the electric grid. |
| IOR | Inspector of Record. |
| IRS | Internal Revenue Service. |
| ITC | Investment Tax Credit – a federal tax credit with special provisions for renewable energy projects. |
| NEM2 | Net Energy Metering 2.0 – net energy metering allows an electricity customer to generate electricity behind their utility meter and export excess production to the utility electrical grid and receive full retail tariff value for exported energy, minus non-bypassable charges. NEM credits are trued-up over a 12-month period. |
| NEM3 | Net Energy Meter 3.0 – a proposed subsequent tariff to NEM 2.0 |

| | |
|------|--|
| NEMA | Net Energy Metering Aggregation – a utility program that allows for a single electricity customer to benefit from net energy metering over multiple eligible meters on the same property, or on adjacent or contiguous properties. |
| O&M | Operations and Maintenance. |
| PG&E | Pacific Gas & Electric – an investor-owned utility company. |
| PPA | Power Purchase Agreement – a contract to purchase power produced by an independent power producer. |
| PSPS | Public Safety Power Shutoff – a localized grid outage in response to severe weather events in order to prevent wildfires. |
| PTO | Permission to Operate – the final step of the Interconnection Agreement, when the utility provides written approval to operate the generation system. |
| PV | Photovoltaic (system) – a collection of solar modules to convert sunlight into electrical power. |
| RFP | Request for Proposal – a document that describes a project and solicits bids from contractors or developers to complete the work. |
| SGIP | Self-Generation Incentive Program – a utility program in California that provides cash incentives for non-residential customers installing battery storage or generation equipment that can cover up to the full cost of a battery and installation. |
| TELP | Tax-Exempt Lease Purchase – a capital lease using the equipment as collateral. Also referred to as a Tax-Exempt Municipal Lease (TEML) or Muni Lease. |
| TMY3 | Typical Meteorological Year 3 – terrestrial historical monthly average weather/insolation information for specific sites. |